

**Evaluation Report 1000-Door-FPA**  
October 18, 2019

**Product Description:** Series 1000 Wood and Wood Clad Mahogany Outswing Glazed and Solid Doors, with or without Sidelites and/or Transom

**Manufacturer:** Oliveri Millworks (OWW LLC), 3001 Tuxedo Ave., West Palm Beach, FL

**Statement of Compliance:** This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 6<sup>th</sup> Edition (2017) Florida Building Code including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

**Technical Documentation:**

- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing E-13-12018-D, signed and sealed by Lucas A. Turner, P.E
- 3) Test Reports ESP013300P/-1/-2 and ESP013599P/-1 (signed/sealed by Ramesh Patel, P.E.) from Element Materials Technology, Wausau, WI, and TEL 03602027 (signed/sealed by William Shelton, P.E.), from Testing Evaluation Laboratories, Plant City, FL, with Testing Performed: TAS 201/202/203 1994
- 4) Supplemental Calculations to support E-13-12018-D, signed and sealed by Lucas A. Turner, P.E.

**Installation:** Units must be installed according to approval document E-13-12018-D.

**Limitations of Use:** This product:

- ) May be used up to the sizes and configurations, with glazing or panel types with maximum sizes as shown in E-13-12018-D
- ) Achieves design pressures of up to +60/-60 psf
- ) Is Large Missile Impact Resistant and does not require the use of shutters
- ) May be used in the High Velocity Hurricane Zone
- ) Requires Saflex CP Interlayer with PET core per Miami-Dade NOA #18-0301.06 in 7/16 lami and I.G. lami options and Saflex clear or color PVB interlayer per Miami-Dade N.O.A. #17-0712.05 in 9/16 lami option, with lami as indicated in E-13-12018-D.
- ) Requires wood framing as indicated in E-13-12018-D

**Certification of Independence:** I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Oliveri Millworks or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



*LT*  
10/18/2019  
Lucas A. Turner, P.E.  
FL PE #58201